



Bollard Post specifications found in International Fire Code

Section 312 Vehicle Impact Protection

312.2 Posts. Guard posts shall comply with all of the following requirement:

1. Constructed of steel not less than 4 inches in diameter and concrete filled

2. Spaced more than 4 feet between posts on center

3. Set not less than 3 feet deep in a concrete footing of not less than a 15 inch diameter

4. Set with the top of the posts not less than 3 feet above ground