

Mast Arm length 6' - 12'
Curb Overhang 6" min - 7.5' max

LED Cobra Head Luminaire

Mast Arm

Light Standard

APPLICATION	LUMENS
Residential	9,500
Collectors	22,000
Arterials	50,000

Hand hole to face street
4" x 6 1/2" with removable cover

Finished Grade

Bolts shall protrude 4" - 4 1/2"
above foundation.

1/4" min.
bolt clearance

Galvanized Anchor Bolts per
Manufacturers Recommendations.
Use Two leveling nuts with washers
(all Galv.) on each bolt.

ANCHOR BASE FOUNDATION

N.T.S.

Precast Base, or Poured
in Place Concrete Per
Manufacturers Recommendations.

1" Galvanized
Steel Conduit
with 90° Bend

Notes:

1. See Standard Drawing M-15 for Street Lighting Notes.
2. Luminaire type to be approved by the City Engineer.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:	
				<p>PEDESTAL MOUNT LIGHT STANDARD</p>	 CITY ENGINEER, PE 10804
			DWG NO.		M-13