

1. All work shall conform to the requirements of Division 800 of the "Idaho Standards for Public Works Construction" (ISPWC). latest edition.
2. The upper twelve inches (12") of subgrade shall be compacted to a relative compaction of 95%.
3. Prior to placing base material, the following shall be completed:
  - A. Provide compaction test results for all utility trenches, subgrade, and areas under curb and gutter to the City's Engineering Inspector.
  - B. Obtain authorization from the City Inspector to proceed with placement of base material. The City Engineer shall be notified at least forty-eight (48) hours prior to placement of base material.
  - C. Prior to placing base, the subgrade shall be proof-rolled and observed by the City's Streets & Engineering Inspector.
4. Compaction of the crushed aggregate base shall conform to the requirements of Section 802, Part 3.4 of the ISPWC, latest edition.
5. Compaction of the aggregate base shall be tested and approved by a qualified engineer prior to placement of asphaltic concrete.
6. A tack coat shall be applied to the adjacent curbs prior to placement of asphaltic concrete.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
			<b>PAVEMENT NOTES</b> <b>PAGE 1</b>	 CITY ENGINEER, PE 10804
				DATE: 6/20/18
				DWG NO. M-24