



GENERAL NOTES

1. Special backfill material for wells shall consist of washed gravel graded from 1" to 3" with a maximum of 5% passing the No. 200 screen, as measured by weight.
2. Space multiple drains 10' apart and 10' from driveways and curb inlet aprons.

 <p>City of Coeur d'Alene IDAHO</p>	<p>CITY OF COEUR D'ALENE STANDARD DRAWING</p>	<p>APPROVED BY:</p>
	<p>SWALE DRAIN</p>	<p><i>Chris Bodley</i> 10/1/24</p> <p>CITY ENGINEER, PE 10804 DATE:</p>
		<p>DWG NO. SD-11</p>