



SECTION

Not to Scale

NOTES

1. For trenching in improved streets, see Standard Drawing M-11 for trench resurfacing.
2. (*) indicates minimum relative compaction using modified proctor (ASTM D-1557).
3. Bedding Material shall be Sand, Gravel, crushed Aggregate, or Native Granular material having a sand equivalent of not less than 30.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:	
				PIPE BEDDING AND BACKFILL FOR STORM DRAINS	<i>Chris Bodley</i>
			CITY ENGINEER, PE 10804		DATE:
			DWG NO.		SD-8