



FLANGED PIPE, 4" MINIMUM, WILL BE RESTRAINED TO LAST MECHANICAL JOINT AT TEE. DO NOT USE VAULT WALL AS THRUST BEARING SURFACE.

PLAN NOTES:

GATE VALVE TO BE INSTALLED AT HOT TAP TO WATER MAIN

3" OR LARGER METER IN VAULT WILL BE RADIO READ

PLAN VIEW

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
			4" AND LARGER SERVICE SETTING	<i>Chris Bosley</i> 4/13/18
				CITY ENGINEER, PE 10804 DATE:
			IRRIGATION VAULT	DWG NO. W-16