


AIR GAP - MINIMUM OF TWICE
 THE INLET PIPE DIAMETER
 ABOVE THE FLOOD RIM BUT
 NEVER LESS THAN 1 INCH.



REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
			APPROVED AIR GAP	<i>Chris Bosley</i> CITY ENGINEER, PE 10804
				4/13/18 DATE:
				DWG NO. W-27