

36" MANHOLE WATER
TIGHT LID, TRAFFIC RATED
AS REQUIRED.

36"

GRADE

2" THREADED CAP

WELL
CASING

APPROVED
WELL CAP,
WELDED
OR
RESILIENT
SEAL 6"
BELOW
LID.

5" THICK
CONCRETE
VAULT

24"

2" DRAIN PIPE EXTENDED TO
AN APPROVED DRAINFIELD.

PREVIOUSLY
ABANDONED WELL
CASING

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
				MONITORING WELL MODIFICATIONS
			4/13/18 DATE:	
			DWG NO. W-28	