



APPROVED TAPPING METHOD:

1. ROMAC DOUBLE STAINLESS STEEL SADDLE TAP
2. SEE STD DWG W-1 FOR TAPPING DETAILS

NOTE: CURB STOP BOX SETTINGS

- A. ONLY CAST IRON CURB STOP BOXES SHALL BE USED.
- B. LID SHALL BE AT FINISHED GRADE.
- C. LID SHALL HAVE "WATER" IMPRINTED ON LID.

ITEM NO.	NO. REQD.	DESCRIPTION
1	1	CAST IRON CURB STOP BOX
2	3	1" BRASS PACK JOINT ASSEMBLY
3	1	1" x REQD. LENGTH -- USE IRON PIPE SIZE POLYETHYLENE HDPE (200 PSI)
4	1	1" x REQD. LENGTH (STOPPING AT PROPERTY LINE)- USE PIPE SIZE GALV. OR IRON PIPE SIZE POLYETHYLENE PIPE
5	1	1" BRASS CURB STOP WITH PACK JOINT ASSEMBLY.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
			1" - 2" CURB STOP C.I. BOX ASSEMBLY	 CITY ENGINEER, PE 10602
				DATE: 4/13/18 DWG NO. W-5