




CONSTRUCTION SPECIFICATIONS

1. Stone size: 2" stone or reclaimed or recycled concrete equivalent.
2. Length: as required to prevent dirt tracking from site, but not less than 50 feet (except 20 foot minimum on a single family residence).
3. Thickness: not less than 6 inches.
4. Width: 10 foot minimum, but not less than the full width of ingress and egress locations.
5. Filter fabric shall be placed over the entire area prior to placing of stone. Filter cloth will not be required on a single family residence lot.
6. Surface water: all surface water flowing or diverted toward construction entrances shall be piped across the entrance. If piping is impractical, a mountable berm with 5:1 slopes will be required.
7. Maintenance: the entrance shall be maintained in a condition which will prevent tracking or flowing of sediment onto public right-of-way. This may require periodic top dressing with additional stone as conditions demand and repair and/or cleanout of any measures used to trap sediment. All sediment spilled, dropped, washed or tracked onto public right-of-way must be removed immediately.
8. Washing: wheels shall be cleaned to remove sediment prior to entrance onto public right-of-way. When washing is required, it shall be done in an area stabilized with stone and which drains into an approved sediment trapping device.
9. Periodic inspection and needed maintenance shall be provided after each rain.



CITY OF COEUR D'ALENE STANDARD DRAWING

STABILIZED CONSTRUCTION ENTRANCE

APPROVED BY:

Chris Bosley
CITY ENGINEER, PE 10804

6/8/16
DATE:

DWG NO.

M-18