




NOTES:

1. BACKFLOW ASSEMBLY MUST MEET U.S.C./IDAPA STANDARDS AND SPECIFICATIONS.
2. ASSEMBLIES MUST BE INSTALLED IN THEIR APPROVED ORIENTATION ONLY.
3. THE ASSEMBLY SHALL HAVE THE MINIMUM PERIMETER OF SPACE AROUND THE ASSEMBLY AT ALL TIMES AND MUST HAVE ADEQUATE ACCESS AT ALL TIMES FOR TESTING AND MAINTENANCE OF ASSEMBLY, MIN. 12" FOR NON TEST SIDE, 24" FOR THE TEST SIDE.
4. TEST COCKS ARE REQUIRED TO FACE AWAY FROM WALLS AND NEAREST STATIONARY OBJECT, AND AT NO TIME BE LESS THAN 24" CLEARANCE.
5. THERE MUST BE NO UNPROTECTED BRANCH PIPING OR TEES CONNECTED TO THE SUPPLY PIPE BETWEEN THE CITY SERVICE SUPPLY LINE AND THE ASSEMBLY IF USED FOR BUILDING ISOLATION.
6. ALL MEASUREMENTS ARE FROM THE LOWEST OR WIDEST PART OF THE ASSEMBLY.
7. ALL ASSEMBLIES ARE SUSCEPTIBLE TO FREEZING AND SHALL BE ADEQUATELY FREEZE PROTECTED.
8. BACKFLOW ASSEMBLY MUST BE INSTALLED WITHIN 2' OF FLOOR OR WALL SERVICE PENETRATION.



CITY OF COEUR D'ALENE STANDARD DRAWING

**TYPICAL APPROVED DC
FOR BUILDING ISOLATION**

APPROVED BY:

Chris Bosley
CITY ENGINEER, PE 10804

3/23/26
DATE:

DWG NO.

W-38